



From

The District fire officer,

To, SANJAY AGARWAL,

DRS INTERNATIONAL SCHOOL CAMPUS SURVEY

NO:523 OPP:APPAREL PARK GUNDLA

POCHAMPALLY MADCHAL MANDAL TELANGANA

Medchal District.	POCHAMPALLY MADCHAL MANDAL TELANGANA STATE,
	ck. No.579320002025 Dated:22/07/2025
Sir,	
Sub:	langana Fire, Disaster Response, Emergency Civil Defence Department —Medchal strict. Renewal of No Objection Certificate of Occupancy to the Non Multi storeyed milding of DRS INTERNATIONAL CHOOL, DRS INTERNATIONAL CHOOL CAMPUS SURVEY NO:523 PP:APPAREL PARK GUNDLA OCHAMPALLY MADCHAL MANDAL ND DISTRICT TELANGANA STATE/- undlapochampally/Medchal/Medchal, — egarding.
Ref:	Acknowledgement No 579320002025 This Office NOC for Occupancy Ack/RC No.Rc.No:335040002020 dt.22/07/2025 Non Multi storeyed Building Inspection Committee Report,. ck. No. 579320002025, dt. 22/07/2025
Ref:	Non Multi storeyed Building Inspection Committee Report,.

- The Non Multi storeyed Building Inspection committee, vide reference cited (3) has inspected the Non Multi storeyed Building of DRS INTERNATIONAL SCHOOL, DRS INTERNATIONAL SCHOOL CAMPUS SURVEY NO:523 OPP:APPAREL PARK GUNDLA POCHAMPALLY MADCHAL MANDAL AND DISTRICT TELANGANA STATE/-Gundlapochampally/Medchal/Medchal
- 2) The above said building was issued was issued No Objection certificate vide reference cited (2) for Non Multi storeyed Building with 1 Cellars, 1 Ground, 3 Floors, with a height of 14.90 Meters for EDUCATIONAL B-1 Schools up to senior secondary level Occupancy.
- 3) Now the Builder/Authorized person has requested to issue Renewal of No Objection Certificate for Occupancy to the Non Multi storeyed Building with 1 Cellars, 1 Ground, 3 Floors, with a height of 14.90 Meters for EDUCATIONAL B-1 Schools up to senior secondary level Occupancy

Open	Spaces:The builder provided the following	Open spaces as per Noc occupancy	Open spaces provided now
SI.No	Side	6.00	6.00
1	North	THE STATE OF THE PROPERTY OF T	6.00
2	South	6.00	6.00
2	East	6.00	and the Control of th
3	from the district of the control of	4.00	4.00
4	West	The second secon	provided now
SI. No	Gate Width As per Occupancy NOC	as per Noc occupancy	6.00
1	Entry gate width	6.00	with the second section of the second section of the second second second second section of the second section of the second second section of the second se
-	Entry Gate Head Clearance	5.00	5.00
2		6.00	6.00
3	Exit Gate Width	THE STATE STATE OF THE PROPERTY OF THE PROPERT	5.00
1	Exit Gate Head Clearance	5.00	The second secon

5) Travel Distance





	Item / Description	as per Noc occupancy	provided now
1	Farthest point (Most Remote Point) With in a storey or a mezzanine floor to the door to an Exit.	41.00	41.00
2	The Dead end of the corridor length in exit access. (6 mtrs for Educational, Institutional and Assembly, 15mtrs for other Occupancies)	6.00	6.00

6) Stair Cases (As per Occupancy NOC):

Sl.no.	Type of staircases	Total width	No of staircases	Floors from	Floors to
1	Internal staircases	1.50	2	Cellar	Ground
2	Internal staircases	1,60	2	Ground	3rd Floor
3	External staircases	1.50	1	Ground	Теттасе

SI.no	Floor type	Buil-up Area in Sq.Mtrs	Type of Occupancy	Occupan t Load	Means of escape required as per Occupancy NOC	Means escape available now
l	Cellar	753.44	Parking	188.00	3.00	3.00
2	Groun d	1379.14	EDUCATIONAL B-I Schools up to senior secondary level	345.00	4.70	4.70
3	1st Floor	1379.14	EDUCATIONAL B-1 Schools up to senior secondary level	345.00	4.70	4.70
4	2nd Floor	1379.14	EDUCATIONAL B-1 Schools up to senior secondary level	345.00	4.70	4.70
5	3rd Floor	1379.14	EDUCATIONAL B-1 Schools up to senior secondary level	345.00	4.70	4.70
	Total	6270.00			The second of th	

8) Fire Shaft as per Occupancy NOC:

9) Floor Wise details of Fire Fighting Installations:

Sl.n o	Floor Details	Fire Extinguishe	Hose Reel	Automatic Sprinklers System	Manually Operated Electronic Fire Alarm System	Automate detection and alarm system
l	Cellar	5.00	1.00	36.00	0.00	0.00
2	Ground	10.00	2.00	0.00	0.00	0.00
3	1st Floor	10.00	2.00	0.00	0.00	0.00
4	2nd Floor	10.00	2.00	0.00	0.00	0.00
5	3rd Floor	10.00	2.00	0.00	0.00	0.00

10) Fire Fighting Installations As per Occupancy NOC: Fire Fighting System.	Required As per Occupancy NOC	Provided
	45	45
Fire Extinguishers	13	13
First Aid Hose Reel		Control to the Paint Management Andrews
Down Comer	2	2





Automatic Sprinkler System	36	36
Manually Operated Electronic Fire Alarm Systems	10	10
Capacity of Terrace Tank over Respective Tower Terrace in Litres	15000	15000
Pump capacity in LPM at the Terrace Tank level with min Pressure of 3.5 Kg/CM^2	900	900
No. of Terrace Tanks over Respective Tower in ltrs	1	I
No. of Pumps at the Terrace Tank level with min pressure of 3.5 Kg/Cm^2	I	1

11). The Non Multi storeyed Building Inspection Committee have reported that the Management has provided the Fire Safety Measres and there is no deficiencies.

12. Remarks:

Approver as recommended by the inspection committee.

13) In view of the above and as per recommendations of the Non Multi storeyed building inspection Committee, the Renewal of No Objection Certificate for occupancy is issued to Non Multi storeyed Building with **DRS**

INTERNATIONAL SCHOOL, DRS INTERNATIONAL SCHOOL CAMPUS SURVEY NO:523 OPP:APPAREL PARK GUNDLA POCHAMPALLY MADCHAL MANDAL AND DISTRICT TELANGANA STATE/-

Gundlapochampally/Medchal/Medchal

with a height of 14.90 Meters for EDUCATIONAL B-1 Schools up to senior secondary level Occupancy subject to the following conditions

SI No	Builder and Management Body	Occupant	Management Body and fire and security personnel
ı	 -a) All the fire protection arrangements shall be maintained in good condition as seen during inspection. -b) Do's and Don'ts in case of fire shall be prominently displayed in entire building 	· -	All the occupants must know the correct method of operation of the fire fighting systems installed.
2	Any loss of life or property due to non- functioning of fire safety measures and other installations shall be the responsibility of the management.	All occupants shall be trained to operate the fire safety equipment during emergency.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.
3	Addition / alteration, if any in the building may be verified by building authority.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.	All security personnel shall be trained to operate the fire safety equipment during emergency and guiding the occupants in safe evacuation. Call the fire Brigade by dialing 101.
4	This No objection Certificate for occupancy is valid for Five Years from the date of issue of this letter.	Raise the alarm if the fire cannot be controlled, evacuate the area completely at once from the nearest safe exit.	Attack the fire using available fire equipment only if you feel capable of controlling it. If not, take all steps to isolate the area by closing doors and windows.

This Renewal of No Objection Certificate for Occupancy is valid for Five Years from the date of issue of this letter. It is the responsibility of the builder to apply for renewal NOC, duly remitting the user charges as per G.O. Ms. No. 71, Home (Prison – A) Department, dated 01-04-2010, two months before expiry of this No Objection Certificate.







"THIS IS COMPUTER GENERATED DOCUMENT AND DO NOT REQUIRE ANY STAMP OR SIGNATURE"
Signed By: Mr.P. Jaya Krushna

Designation: District Fire Officer, Hazmat

Date: 22-07-2025 Medchal District.

Copies to:

i) The Management

ii) Non Multi storeyed Building Inspection Committee

iii) Copy submitted to Regional Fire officer

iv) Copy submitted to DG fire services

Managér Signature

Principal Signature

For DRS International School

'Authorised Signalery